

THE INFRA RED SETTING TOOL ENABLES ALL CONFIGURABLE ACTUATOR SETTINGS TO BE MADE.

BEFORE PUTTING THE ACTUATOR INTO SERVICE, IT MUST BE INSTALLED AND COMMISSIONED IN ACCORDANCE WITH PUBLICATION E170E : IQ INSTALLATION AND MAINTENANCE INSTRUCTIONS.
UNLESS SPECIFIED WITH ORDER, THE ACTUATOR IS DESPATCHED WITH DEFAULT SETTINGS AS LISTED IN PUBLICATION E170E.

FOR IQ CONTROL AND MONITORING FACILITIES, REFER TO PUBLICATION E420E.

REMOTE CONTROL CIRCUITS

REMOTE CONTROLS MAY BE FED FROM AN EXTERNAL SUPPLY LIVE/+VE UP TO 40V AC OR DC, WHEN THE ZERO/-VE OF THE SUPPLY SHOULD BE CONNECTED AS FOLLOWS:-
TO TERMINAL 36 FOR OPEN OPERATION.
TO TERMINAL 40 FOR CLOSE OPERATION.
TO TERMINAL 31 FOR ESD OPERATION.
TO TERMINAL 32 FOR STOP/MAINTAIN & INTERLOCKS.

