



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

P3W Coordinator, P3W Repeater-DC or P3W WMA-DC. Pakscan 3 Wireless Modules

P3W Repeater-AC or P3W WMA-AC. Pakscan 3 Wireless Modules

Equipment Ratings:

P3W Coordinator, P3W Repeaters and P3W WMA, Pakscan 3 Wireless Modules are rated as Explosionproof for Class I, Division 1, Groups B, C and D or Explosionproof for Class I, Division 1, Groups C and D; and Dust-ignitionproof for Class II, Division 1, Groups E, F and G hazardous (classified) locations, indoors and outdoors Type 6. The apparatus are rated for an overall ambient temperature range of -40°C to +60°C and Temperature Class T4. Electrical ratings 35 Vdc / 0.5A max for the -DC versions and up to 480 and 600 Vac, 3Ø, 50 or 60 Hz, or up to 240 Vac, 1Ø, 50 or 60 Hz depending on configuration for the -AC versions.

FM Approved for:

Rotork Controls Ltd.
Bath BA1 3JQ United Kingdom



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3615	2006
Class 3616	2011
Class 3810	2005
ANSI/NEMA-250	1991


Original Project ID: 3044969

Approval Granted: February 20, 2013

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



J.E. Marquedant

Group Manager, Electrical

20 February 2013

Date