

# Certificate of Compliance

**Certificate:** 1169596 (LR 40749)

**Master Contract:** 153247

**Project:** 1169596

**Date Issued:** 2001-6-27


**Issued to:** Rotork Controls Inc.  
675 Mile Crossing Blvd.  
Rochester NY 14624  
USA


**Attention:** Mr. Tim White

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:**

  
Ray Lehman

**Authorized by:**   
Ray Fadavi, P. Eng., MBA  
Operations Manager

## PRODUCTS

CLASS 3221 02 - VALVES - Actuators

Connection Box for use with Actuators, Model Pakbox PB1 MK2, rated up to 600Vac, 20 A, 60Hz, 3 phase or up to 600Vac, 7.5 A, 60Hz, 1 phase, Enclosure CSA Type 4X.

Connection Box for use with Actuators, Model Pakbox PB2 MK2, rated input 120V ac, 20mA, 60Hz; output relay (RLY1 to RLY5) contacts rated 0.4A, 125V ac or 2A, 30V dc, Enclosure CSA Type 4X.

## APPLICABLE REQUIREMENTS

|                   |          |   |                              |
|-------------------|----------|---|------------------------------|
| CSA Std C22.2 No. | 139-1982 | - | Electrically Operated Valves |
| CAN/CSA-C22.2 No. | 94-M91   | - | Special Purpose Enclosures   |