



CSA Group Testing UK Ltd,
Unit 6, Hawarden Industrial Park,
Hawarden, Deeside,
CH5 3US

TEST CERTIFICATE

ISSUED BY CSA GROUP TESTING UK LIMITED

TEST FOR THE INGRESS PROTECTION OF A SI 3.3 ELECTRO-HYDRAULIC ACTUATOR

Manufacturer: Rotork Fluid Systems
9 Brown Lane West
Holbeck
Leeds
LS12 6BH

Model or Type Identification: SI 3.3 electro-hydraulic actuator

Standard: IEC 60529:2013

Deviations from Standard: None

Aim: IP66/68 (7 m for 72 hours)

CSA Test Procedure: LOP 220

CSA Test Reports: N70005452A and 15/0170

Sample delivery date: 21st May 2015

Tests conducted between: 10th June to 9th July 2015

Tests performed at: CSA Group Testing UK Limited, Rake Lane, CH4 9JN (IP66)
CSA Group Testing UK Limited, Hawarden, CH5 3US (IPX8)

This certificate refers to the performance of the test sample when tested against the agreed programme. It does not imply that any other samples or products necessarily comply with the requirements of the test programme.

CSA Group Testing UK Limited being a UKAS accredited test house in accordance with ISO/IEC 17025 has tested the above sample and has found it to meet the requirements of the Ingress Protection Codes: IP66/68 (7 m for 72 hours)

S P CORK
Technical Manager

Dated 17th July 2015

This certificate may only be reproduced in its entirety and without change

Page 1 of 1

Certificate No: CSAUK 70005452BLab
FORM 6240, Issue 11