

Ref. Certif. No.
SE-103711

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory
Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Q Range of actuator


Rotork Controls (India) Private Limited
28 B Ambattur Industrial Estate (N) Chennai,
Tamil Nadu, 600098, India

Same as applicant

Same as applicant

1Ø Rating 110-120Va.c, 50Hz, 220-240Va.c, 50Hz
 110-120Va.c, 60Hz, 220-240Va.c, 60Hz

3Ø Rating 380Va.c, 50Hz, 400Va.c, 50Hz, 415Va.c, 50Hz
 440Va.c, 60Hz, 460Va.c, 60Hz, 480Va.c, 60Hz



CTF Stage 1

Q100, Q300, Q450 & Q650

On-site verification of the production line testing according to Annex F was excluded.

IEC 61010-1:2010+A1
IEC 61010-2-202:2016

2240891KAU-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Signature: 

Leif Mattsson

Date: 20 January, 2020