



# 中国国家强制性产品认证证书



证书编号: 2021322307003808

认证委托人名称: Rotork UK Ltd  
 认证委托人地址: 9 Brown Lane West, Holbeck, Leeds, UK  
 生产者名称: Rotork UK Ltd  
 生产者地址: 9 Brown Lane West, Holbeck, Leeds, UK  
 生产企业名称: Rotork UK Ltd  
 生产企业地址: 9 Brown Lane West, Holbeck, Leeds, UK

产品名称: 控制模块  
 系列、规格、型号: SI3/SI4  
 标准: GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2021年3月16日      有效期至: 2026年3月15日

首次发证日期: 2021年3月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准:



## 上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2021322307003808**

**APPLICANT:** Rotork UK Ltd  
**ADDRESS:** 9 Brown Lane West, Holbeck, Leeds, UK  
**MANUFACTURER:** Rotork UK Ltd  
**ADDRESS:** 9 Brown Lane West, Holbeck, Leeds, UK  
**FACTORY:** Rotork UK Ltd  
**ADDRESS:** 9 Brown Lane West, Holbeck, Leeds, UK

**PRODUCTNAME:** Skilmatic Range of Electro-Hydraulic Control Modules  
**SERIES,SPECIFICATION,MODEL:** SI3/SI4  
**STANDARDS:** GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**March 16, 2021

**Valid until:** March 15, 2026

**Date of original certification:**March 16, 2021

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA’s website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0004656



# 中国国家强制性产品认证证书



**SITIiAS**  
Worldwide Access

证书编号: 2021322307003808

## 附 件

产品名称: 控制模块

型号规格: SI3/SI4

防爆标志: Ex d IIB/IIC T4 Gb, Ex d e IIB/IIC T4 Gb

电气参数: 额定电压: 24 VDC 或 575 VAC。频率: 50 或 60 Hz。

批 准:



## 上海仪器仪表自控系统检验测试所有限公司