



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

### **RHS, IQ3 Remote Hand Station**

XP / I / 1 / CD / T4 Ta = -50°C to 70°C; XP / I / 1 / BCD / T4 Ta = -50°C to 70°C  
XP / I / 1 / IIB + H<sub>2</sub> / T4 Ta = -50°C to 70°C; DIP / II / 1 / EFG / T4 Ta = -50°C to 70°C  
Type 4 and 6.

### Special Conditions of Use:

*This IQ3 Remote Hand Station shall only be used for the remote control of the IQ3 and IQT3 series actuators.*

### Equipment Ratings:

Explosionproof for Class I, Division 1, Groups C and D or Groups B, C and D; Explosionproof for Class I, Zone 1, Group IIB + H<sub>2</sub>; and Dust-ignitionproof for Class II, Division 1, Groups E, F and G Hazardous (Classified) Locations, indoors and outdoors ratings Type 4 or 6. The overall ambient temperature range is -50°C to +70°C and Temperature Class is T4.

### FM Approved for:

Rotork Controls Ltd  
Bath, United Kingdom



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM3600	2011
FM3615	2006
FM3616	2011
FM3810	2005
ANSI/NEMA 250	2008

Original Project ID: 3054426

Approval Granted: December 16, 2015

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

J.E. Marquedant  
Manager of Electrical Systems

16 December 2015

Date