



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO. GYJ11.1599X

This is to certify that the product

Smart Valve Positioner

manufactured by

YOUNG TECH CO., LTD.

(Address: #662-8, Pungmu-Dong, Kimpoo-City, Keonggi-Do, Korea)

which model is

YT - 3300 *a b i c d e f g*

Ex marking

Ex ia II CT5/T6

product standard

-

drawing number

S3300 - 01 REV.0、S3300 - 02 REV.0、S3300 - 03 REV.0

has been inspected and certified by NEPSI, and that it conforms

to

GB3836.1 - 2010, GB3836.4 - 2010、GB3836.20 - 2010

This Approval shall remain in force until 2017.03.24

Remarks

1. When the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use are specified in the attachment to this certificate.
2. Approved types and special requirements are specified in the attachment to this certificate.
3. Intrinsic safety electrical parameters:
Main Power: Ui: 28V Ii: 93mA Pi: 651mW Ci: 0.5nF Li: 0.3mH
PTM Power: Ui: 28V Ii: 93mA Pi: 651mW Ci: 57.5nF Li: 0.3mH

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2012.03.25



This Certificate is valid for products compatible with the documents and samples approved by NEPSI.