



Sira Test & Certification Ltd, a CSA International company, provides the following services:

- SAFETY TESTING
- ENVIRONMENTAL TESTING
- TRAINING
- HAZARDOUS AREA CLASSIFICATION
- PRODUCT CERTIFICATION SERVICES
- FUNCTIONAL SAFETY

Rake Lane, Eccleston Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com

TESTS UNDERTAKEN AND REPORT PREPARED BY SIRA TEST & CERTIFICATION LIMITED

Author: S C Finch IEng MIIE MInstMC Senior Certification Engineer

Technical Approval: S Cork BSc CEng MInstMC

Laboratory Manager

- Luty d

Date: 15th February 2013

Ingress Protection tests on an Electric Valve Actuator for Rotork Controls Ltd Report No: R15000-062A/00A Commercially in confidence

Copyright © Sira Test & Certification Ltd 2013 The contents of this document are subject to the terms and conditions of Sira Test & Certification Ltd available free on request.

Page 1 of 6

Registered in England: No 05569145

Form 6154, Issue 9

CONTENTS

Section	Title	Page
1	Introduction	3
2	Description of test samples	4
3	Tests for first characteristic numeral 6	5
4	Tests for second characteristic numeral 6	5
5	Tests for second characteristic numeral 8	6
6	Conclusion	6





RAKE LANE, ECCLESTON CHESTER, CH4 9JN, ENGLAND TELEPHONE: 01244 670900 FAX: 01244 681330

TEST REPORT

ISSUED BY SIRA TEST & CERTIFICATION LIMITED

Carried out by ST&C on behalf of:

Rotork Controls Ltd Brassmill Lane Bath BA1 3JQ

Project No: 15000-062

Commercially in confidence

1 INTRODUCTION

This report refers to the performance of the test sample when tested against the agreed programme. Whilst this report maybe freely reproduced as a complete document it may not be abstracted.

Manufacturer: Rotork Controls Ltd

Type Identification (Serial Nos.): IQIII Size 1 Actuator 15000-051 #56

IQIII Size 1 Actuator 15000-051 #103

IQIII Sixe 1 Electrical cover 15000-051 #105

IQIII Size 1 Actuator 15000-062 #1

Standard: BS EN 60529:1992

Deviations from Standard: None

Aim: IP66

IPX8, Depth 7 m, 72 h with the terminal lid fitted IPX8, Depth 7 m, 72 h without the terminal lid fitted

ST&C Test Procedure: LOP 220.08 IP6X

LOP 220.16 IPX6 LOP 220.18 IPX8

ST&C Internal Test Reports: IP6X 12/0200

IPX8 12/0482 - Terminal lid in place

IPX6 12/0483

IPX8 12/1032 - Terminal lid removed

Page 3 of 6

R15000-062A/00 Form 6154, Issue 9 Sample Delivery Dates: 15000-051 #56 24th February 2012

15000-051 #103 21st May 2012 15000-051 #105 13th June 2012 15000-062 #1 30th November 2012

Tests Conducted Between: 8th May and 14th December 2012

2 DESCRIPTION OF TEST SAMPLES

The IQ range of Electric Valve Actuator comprises an oil filled worm gearcase with handwheel and de-clutch mechanism to which is attached a motor enclosure, an electrical control enclosure and a terminal enclosure.

The motor cover connects to the gearcase by means of a spigoted joint and is secured by four M8 capscrews.

The electrical cover connects to the gearcase by means of a spigoted joint and is secured by four M8 capscrews. At one end of the electrical enclosure a window is provided to allow the external observation of an internal LCD device. The window is manufactured from polycarbonate.

The terminal enclosure connects to the electrical enclosure via the gearcase, their volumes being separated by a terminal bung. The terminal bung comprises of moulded plastic main body through which passes a number of moulded in terminals. The terminal bung is secured in position by means of a circlip. The terminal enclosure provides all electrical field-wiring terminations at the terminal bung. Cable entry facilities are provided in the form of three or four threaded entries. The terminal enclosure is closed by means of a lid, which connects to the gearcase by means of a tapered spigot joint and is secured by four M8 capscrews.

In all cases environmental sealing is provided by elastomeric seals. All enclosures are maunufactured in aluminium alloy

3 TESTS FOR FIRST CHARACTERISTIC NUMERAL 6

Test performed on sample 15000-051 #56.

3.1 Test for protection against access to hazardous parts

Reference BS EN 60529:1992 clause 12.

A rigid test wire Ø 1 mm and length to a stop face of 100 mm was pushed against all openings of the test sample with a force of 1 N \pm 10%.

3.1.1 Result

The test wire did not come into contact with any hazardous parts.

3.2 Test for protection against solid foreign objects

Reference BS EN 60529:1992 clause 13.

The test sample was supported in its normal operating orientation inside a chamber containing approximately 2 kg of test dust per cubic metre, with maximum particle size 75 µm maintained in suspension. As the normal working cycle of the test sample may cause a reduction in its internal air pressure below that of the surrounding atmosphere (which was not verified by Sira Test & Certification Ltd) connection was made to a vacuum pump to maintain an under-pressure inside the test sample which did not exceed 20 mbar.

The extraction rate measured was such that the test duration was 8 hours.

3.2.1 Result

On internal inspection of the test sample no dust was found.

4 TEST FOR SECOND CHARACTERISTIC NUMERAL: 6

Tests performed on samples 15000-051 #105 and 15000-051 #103. Two tests were performed; initial test was carried out on sample #103 (excluding the electrical compartment) with the second test being carried out #103 fitted with the electrical cover from #105 (just the electrical compartment under test).

The test method was the same for both tests.

4.1 Test for protection against water

Reference BS EN 60529:1992 clause 14.

The test sample was supported in its normal operating orientation. Water from a standard water jet hose test nozzle with internal \varnothing 12.5 mm was directed at the test sample from all practicable directions at a rate of 100 L/min from a distance between 2.5 to 3 metres. The test duration was 3 minutes.

4.1.1 Result

For both tests, on internal inspection of the area tested no water was found.

5 TESTS FOR SECOND CHARACTERISTIC NUMERAL: 8

Test performed on sample 15000-051 #103 (terminal lid fitted) and 15000-062 #1 (terminal lid removed).

The test method was the same for both tests.

5.1 Test for protection against water

Reference BS EN 60529:1992 clause 14.

5.1.1 With the terminal lid fitted

The test sample was completely immersed in water. A pressure was applied to the water surface so that the lowest point of the sample was subjected to a water level equivalent to at least 7 m. The test duration was 72 hours.

5.1.1.1 Result

Upon internal inspection no water was found within the motor or electrical compartments.

There was evidence of water ingress into the terminal compartment. However subsequent inspections revealed that the ingress was due to badly secured cable entry adaptors and blanking elements, which were not themselves part of the testing requirement.

5.2.1 Without the terminal lid fitted

The test sample was completely immersed in water. A pressure was applied to the water surface so that the lowest point of the sample was subjected to a water level equivalent to at least 7 m. The test duration was 72 hours.

5.2.1.1 Result

On internal inspection of the test sample no water was found.

6 CONCLUSION

The test samples described in sections 1 and 2, when tested in the manner described in sections 3 and 4, satisfied the requirements of BS EN 60529:1992 Amendments Nos. 1 and 2 as detailed below:

IP66, complete device

IPX8 at a water depth of 7 metres for 72 hours, complete device.

IPX8 at a water depth of 7 metres for 72 hours, with the terminal lid removed.

The other sizes in the IQ Range employ similar environmental sealing arrangements and materials of construction. Although not tested as part of the above programme the IQ Range can be considered as maintaining the above levels of ingress protection.